



SECTION A
SCALE 1:40
2-1



MATERIAL SCHEDULE			
ITEM NO.	QTY	DESCRIPTION	SUPPLIER/ MANUFACTURER
1	2	NOGGERATH CENTRE-FLO BAND SCREEN	AOSEPTENCE (PRINCIPAL SUPPLIED)
2	1	FEED HOPPER INC. DRAINER NECK	AOSEPTENCE (PRINCIPAL SUPPLIED)
3	1	COMMON SCREENINGS LAUNDRER	AOSEPTENCE (PRINCIPAL SUPPLIED)
4	1	STOP BOARD IN CONCRETE RECESS (1030mm x 1000mm)	REFER TO DRAWING 1034-03-08-DWG-015
5	2	316SS GUIDE FRAME INC. DLF DOWNWARD OPENING PENSTOCK (600mm x 600mm)	AWMA OR APPROVED EQUIVALENT
6	4	316SS GUIDE FRAME INC. ULF PENSTOCK (1000mm x 1000mm)	AWMA OR APPROVED EQUIVALENT
7A	1	END PIPE SS316 WITH PUDDLE FLANGE CONNECTIONS DN500 DN600 DN750 DN450 DN450	REFER TO DRAWING 1034-03-08-DWG-014
7B	2		
7C	1		
7D	2		
7E	2		
8	4	RESTRAINED COUPLING SS316 PN16 (REFER TO NOTE 2)	AVK SUPA-GIB STEP/ STRAIGHT COUPLING OR APPROVED EQUIVALENT
9	1	DN250 MAG METER W/REMOTE DISPLAY ON FIELD MOUNTED STAND SIEMENS MAG5100 OR APPROVED EQUIVALENT	SIEMENS OR APPROVED EQUIVALENT
10	2	DN450 MAG METER SIEMENS MAG5100 OR APPROVED EQUIVALENT	SIEMENS OR APPROVED EQUIVALENT
11	4	DN450 KNIFE GATE VALVE	AVK OR APPROVED EQUIVALENT
12A	2	DN450 SS316 FLANGED PIPE SPOOLS	REFER TO DRAWING 1034-03-08-DWG-014
12B	2		
13	VARIOUS	FRP GRATING INC. SUPPORTS, IN ACCORDANCE WITH WATER CORP. STANDARD DS100 & AS 1657.	TREADWILL OR APPROVED EQUIVALENT
14	VARIOUS	FRP VINYL ESTER RESIN GUARDRAILING MOUNTED ON CONCRETE WALLS/KERBS, IN ACCORDANCE WITH AS1657	-




SECTION B
SCALE 1:40
2-1



SECTION D
SCALE 1:40
2-1



SECTION C
SCALE 1:40
2-1



SECTION E
SCALE 1:40
2-1

- NOTES
- TRENCH WIDTHS SHALL NOT EXCEED THE MINIMUM PRACTICABLE TO CARRY OUT COMPACTION AND PIPE LAYING ADEQUATELY AND SAFELY
 - EXISTING PIPE SIZES TO BE VERIFIED BY CONTRACTOR PRIOR TO COUPLING PROCUREMENT.

ISSUED FOR TENDER

3	19.04.24	DIMENSIONS AND DETAILS ADDED	BD	MW	BD	GD	CKB				DRAWN:	RB	DATE:	FEB. 2023	CITY OF KALGOORLIE-Boulder SOUTH BOULDER WWTP INLET WORKS GENERAL ARRANGEMENT SECTIONS
2	01.03.24	ISSUED FOR TENDER	BD	MW	BD	GD	CKB				CHECKED:	PH	DATE:	FEB. 2023	
1	DEC. 2023	ISSUED FOR CLIENT REVIEW	BD	MW	BD	GD	CKB				DESIGNED:	PH	DATE:	FEB. 2023	
0	MAR. 2023	ISSUED FOR EQUIPMENT SUPPLY TENDER	RB	PH	PH	GD	CKB				APPROVED:	GD	DATE:	FEB. 2023	
A	FEB. 2023	DRAFT FOR CLIENT REVIEW	RB	PH	PH	GD	CKB				CLIENT:	CKB			
REV	DATE	REVISION DESCRIPTION	DRAWN	CHECKED	DESIGNED	APPROVED	CLIENT	WISE PROJECT NO.	1034-03-08	SCALE:	AS NOTED	DRG No	1034-03-08-DWG-002-2	REV	3